


Sl. No. 5

ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರ ಕಛೇರಿ ನಂ.2ನೇ ಕಟ್ಟಡಗಳ ವಿಭಾಗ, ಲೋಡ್ ಅನೇಕ್ ಕಟ್ಟಡ, 1ನೇ ಮಹಡಿ, ಕೆ.ಆರ್. ವೃತ್ತ, ಬೆಂಗಳೂರು 01.	 ಕರ್ನಾಟಕ ಸರ್ಕಾರ	ದೂರವಾಣಿ : 080-22122856 ಫ್ಯಾಕ್ಸ್ : 080-22123368 ಇ ಮೇಲ್: eebldno2@gmail.com
(ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ)		

ಸಂಖ್ಯೆ:ಕಾನಿಇಂ:ಕವಿ2:ತಾಂಸ:ಸಇಂ-6:23-24

759-61

ದಿನಾಂಕ: 19/05/2023

ಇವರಿಗೆ:

ದಿಯಾ ಅಕಾಡೆಮಿ ಆಫ್ ಲರ್ನಿಂಗ್,
ಸರ್ವೆ ನಂ 70/1 ಮತ್ತು ಸರ್ವೆ ನಂ.71,
ಫೋಡಿಗಹಳ್ಳಿ ಮುಖ್ಯ ರಸ್ತೆ, ಕೆ ಆರ್ ಪುರಂ,
ಬೆಂಗಳೂರು-560036.

ಮಾನ್ಯರೇ,


ವಿಷಯ	2023-2024 ನೇ ಕಟ್ಟಡ ಸುರಕ್ಷತಾ ಪ್ರಮಾಣ ಪತ್ರ ನೀಡುವ ಬಗ್ಗೆ.
ಉಲ್ಲೇಖ	1.ತಮ್ಮ ಮನವಿ ಪತ್ರ ದಿನಾಂಕ: 20-01-2023. 2.ಕರ್ನಾಟಕ ಸರ್ಕಾರ ಸಚಿವಾಲಯದ ಸುತ್ತೋಲೆ ತಿದ್ದುಪಡಿ ದಿ:06-05-22. 3.ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು, ನಂ.6ನೇ ಕಟ್ಟಡಗಳ ಉಪ ವಿಭಾಗ, ಬೆಂಗಳೂರು ರವರ ಕಛೇರಿ ಪತ್ರ ಸಂಖ್ಯೆ:164:22-23; ದಿ:15.05.23.

ಮೇಲ್ಕಂಡ ವಿಷಯಕ್ಕೆ ಸಂಬಂಧಿಸಿದಂತೆ, ಉಲ್ಲೇಖ (1)ರ ಪತ್ರದಲ್ಲಿ ದಿಯಾ ಅಕಾಡೆಮಿ ಆಫ್ ಲರ್ನಿಂಗ್, ಸರ್ವೆ ನಂ 70/1 ಮತ್ತು ಸರ್ವೆ ನಂ.71, ಫೋಡಿಗಹಳ್ಳಿ ಮುಖ್ಯ ರಸ್ತೆ, ಕೆ ಆರ್ ಪುರಂ, ಬೆಂಗಳೂರು-560036, ಕಟ್ಟಡಕ್ಕೆ ಸಂಬಂಧಿಸಿದಂತೆ ಸುರಕ್ಷತಾ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ಕೋರಿರುತ್ತೀರಿ.

ಉಲ್ಲೇಖ (2)ರ ಸರ್ಕಾರದ ಸುತ್ತೋಲೆ ತಿದ್ದುಪಡಿಯ ಅನುಸಾರ ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ ಸಂಹಿತೆಯ ಅನ್ವಯ ಕಟ್ಟಡ ಸುರಕ್ಷತಾ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ಈ ಕಛೇರಿಯಿಂದ ಪಡೆಯಲು ಮೌಲ್ಯ ರೂ.5,000.00 ವನ್ನು (ಡಿಡಿ ಸಂಖ್ಯೆ: 470185 ದಿನಾಂಕ 19-05-2023) ಈ ಕಛೇರಿಗೆ ಸಲ್ಲಿಸಿರುತ್ತೀರಿ.

ಮುಂದುವರೆದು, ದಿನಾಂಕ 07-01-2023 ರಂದು ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು, ನಂ.6ನೇ ಕಟ್ಟಡಗಳ ಉಪವಿಭಾಗ, ಬೆಂಗಳೂರು ರವರು ಸ್ಥಳ ಪರಿವೀಕ್ಷಣೆ ಕೈಗೊಂಡಿರುತ್ತಾರೆ. ಉಲ್ಲೇಖಿತ (3)ರ ಪತ್ರದಲ್ಲಿ ಕೈಗೊಂಡಿರುವ ಪರಿವೀಕ್ಷಣೆ ಹಾಗೂ ಉಲ್ಲೇಖ (2)ರ ಸರ್ಕಾರದ ಸುತ್ತೋಲೆಯನ್ವಯ ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು ಪರಿವೀಕ್ಷಿಸಿ ಶಿಫಾರಸ್ಸು ಮಾಡಿರುವ ಹಿನ್ನೆಲೆಯಲ್ಲಿ, ಸದರಿ ಕಟ್ಟಡದ "STRUCTURALLY STABLE" ಎಂದು ಪರಿಗಣಿಸಿ ನಿರಾಕ್ಷೇಪಣಾ ಪತ್ರವನ್ನು ದಿನಾಂಕ:22.05.2023 ರಿಂದ 21.05.2024 ರ ವರೆಗೆ ನೀಡಲಾಗಿದೆ.

ತಮ್ಮ ವಿಶ್ವಾಸಿ,


ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು,

ನಂ.2ನೇ ಕಟ್ಟಡಗಳ ವಿಭಾಗ, ಬೆಂಗಳೂರು.

PK



Karnataka Power Transmission Corporation Limited

Telephone: 080-29904286
Email : tlsshody@gmail.com
No.EE/HD/TL-SS/AEE(O)/AE(T)/23-24/
TLSD/F-21/ 1223
Encl: EHT Measurement report.



Office of the
Executive Engineer, Elecl.,
KPTCL, TL & SS Division,
Hoody, Bengaluru-560 048.
Date: 12.07.2023.

To,
M/s.Diya Academy of Learning,
Survey No.70/1 & 71,
Kodigehalli Main Road, K.R.Puram,
Bangalore-560 036.

Sir,

Sub:- Issue of EHT Measurement Report.

Ref:- 1. M/s.Diya Academy of Learning letter dated 05.07.2023.
2. Ltr.No.AEE(E)/TL-SD/23-24/027 dated 12.07.2023..

With reference to the above subject, I am here with enclosing the EHT Measurement report of M/s.Diya Academy of Learning, Survey No.70/1 & 71, Kodigehalli Main Road, K.R.Puram, Bangalore-560 036. The actual measurements taken are within permissible limits.

This is for your information and further needful.

Yours faithfully,

Chd N 12/07/2023
Executive Engineer[Elecl.],
KPTCL, TL-SS Division,
Hoody, Bengaluru -560 048.

**KARNATAKA POWER TRANSMISSION CORPORATION LIMITED.
EHT MEASUREMENT REPORT**

Application No: Letter from Diya Academy Of Learning to O/o The Executive Engineer[Elec.,]
TL&SS Hoody DATED: 05.07.2023

1	Name of the Applicant	Diya Academy Of Learning			
2	Address of the location for which EHT clearance is sought for	Survey No.70/1 & 71, Kodigehalli main road, K.R.Puram, Bangalore-560036			
3	Date of Inspection & Time/Amb.Temp.	10.07.2023 at 10:30 Hrs, 26 °C.			
4	Name of the EHT line passing over/running by the side of the building	66 kV Hoody-Hoskote			
5	Location of the building with respect to the location of the tower	Between Tower No 9 & 10			
6	Span length in Mtrs. & Conductor use	230 Mtrs, Coyote Conductor.			
7	Distance of the building to the Either side of the tower in Mtrs.	80 Mtrs from Tower No 9 150 Mtrs from Tower No 10			
8	Load at the time of inspection	27 MW			
9	Whether the sanctioned building plan enclosed or not	No			
10	Inspection and measurement charges Rs.1180/- collected vide Rt.No:2499 Date:-06.07.2022				
Particulars	Clearance Measured from line				
	400kV		Remarks	66kV	
	As Required	As Measured		As Required	As Measured
HORIZONTAL	NA	NA	As per IE Rule 61 of 2010 Building should not be constructed under the line	2.3 Mtr	5.8 Mtr
VERTICAL	NA	NA		NA	NA

Note-1:- Measurement is shown as per actual measurements taken by Hot line staff. Necessary clearance shall be maintained and action may be taken by following Indian Electricity Rules. **The actual measurements taken are within the permissible limit.**

Note-2:-The provisions of clearances as stipulated under Rule 80 of the IE Rules 1956 which are noted above shall be adhered to till the CEA finalizes the CEA (Measures relating to safety and Electric Supply) Regulations, 2007. Thereafter the provisions as in the final notification vide No. KERC/RP/D/07/08 dated 12.03.2008 which was published in Karnataka Gazette dated 20th March 2008 and regulations of CEA shall be adhered to.

Note-3: Clearances from the buildings of lines of voltage exceeding 650V : an overhead line shall not cross over an existing building as far as possible and no building shall be constructed under an existing overhead line under Rule 80 of the IE Rules 1956 and CEA Rule 61 of the IE Rules 2010 .

NO. Alamed
Junior Engineer(Ele.),
KPTCL, TLM Sub-division,
Hoody, Bengaluru-48.

H. Belgaurm 12/7/23
Asst.Executive Engineer (Ele.),
TLM Sub-Division, Hoody,
Bengaluru- 48.

Chellu
Executive Engineer (Ele.),
TL & SS Division, K.P.T.C.L.,
Hoody, Bengaluru - 48.