



BRUHAT BENGALURU MAHANAGARA PALIKE

Office of the Medical Officer of Health Mahadevapura Zone, Bangalore - 560048.

NO: BBMP/MHO/MDP/PR/2024-25

DATE:30/01/2025.

**PERFORMA REGARDING NOC & SAFE DRINKING WATER AND
SANITARY CONDITION CETFIFICATE**

It is certified that an inspection team headed by **Dr.Rakesh .N. Medical Officer of Health** and **Mukundappa.C., HS** from **BBMP Health Department** inspected **DIYA ACADEMY OF LEARNING, Survey No.70/1 & 71, Kodigehalli Main Road, K.R.Puram Bangalore-560036.**(Name & Address of the school) on **30-01-2025** and found that the **DIYA ACADEMY OF LEARNING** (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the central /state/U.T.Govt.

The Above NOC is Valid for the Period of One Year from the date of Issue.

Signature with Seal:

Name

: Dr.Rakesh.N

Designation

: Medical Officer of Health

ಆರೋಗ್ಯ ವ್ಯವಸ್ಥಾಪಕರು
BBMP, Mahadevapura Zone.

ಮಹಾನಗರ ಪಾಲಿಕೆ

ಬೆಂಗಳೂರು

To,

**DIYA ACADEMY OF LEARNING
Survey No.70/1 & 71,
Kodigehalli Main Road,
K.R.Puram
Bangalore-560036**

TEST REPORT

ULR No.TC143092500003213F

Sample Code: NTLPL/3213	Date of Sampling	--
Name Of the Organization :	Date of Receipt	16.01.2025
M/s. DIYA ACADEMY OF LEARNING	Date of Analysis Started	16.01.2025
# 70/1, 71, Kodigehalli Main Road, K.R Puram,	Date of Analysis Completed	19.01.2025
Bangalore - 560036.	Date of Report	22.01.2025
	Environmental Condition	Ambient
Sample Particulars : Filter Water	Sample Drawn By	Customer
Source of Collection : Filter	Report No	NTLPL/3213
Sampling Method : --	Condition of the Sample	Satisfactory

RESULTS

S. No	Parameters	Protocol	Results	Standards IS : 10500 - 2012	
				Desirable Limits	Permissible Limits
1	pH Value @ 25°C	IS 3025 (Part - 11) 2022	6.53	6.5-8.5	No Relaxation
2	Colour, Hazen Unit	IS 3025 (Part - 4) 2021	2.0	5.0 Max	15
3	Odour	IS 3025 (Part - 5) 2018	Agreeable	Agreeable	Agreeable
4	Turbidity, NTU	IS 3025 (Part - 10) 2023	0.1	1.0 Max	5.0 Max
5	Total Dissolved Solids, mg/L	IS 3025 (Part - 16) 2023	29.5	500 Max	2000 Max
6	Total Hardness as CaCO ₃ , mg/L	IS 3025 (Part - 21) 2009 RA 2023	4.0	200 Max	600 Max
7	Calcium as Ca, mg/L	IS 3025 (Part - 40) 2024	0.8	75 Max	200 Max
8	Magnesium as Mg, mg/L	IS 3025 (Part - 46) 2023	0.5	30 Max	100 Max
9	Alkalinity as CaCO ₃ , mg/L	IS 3025 (Part - 23) 2023	8.8	200 Max	600 Max
10	Chlorides as Cl, mg/L	IS 3025 (Part - 32) 1988 RA 2019	6.0	250 Max	1000 Max
11	Sulphates as SO ₄ , mg/L	IS 3025 (Part - 24/Sec1) 2022	1.0	200 Max	400 Max
12	Nitrates as NO ₃ , mg/L	IS 3025 (Part - 34) 1988 RA 2019	3.1	45 Max	No Relaxation
13	Iron as Fe, mg/L	IS 3025 (Part - 53) 2024	0.05	1.0 Max	No Relaxation
14	Fluoride as F, mg/L	APHA 24th Edition 4500 F-D: 2023	0.1	1.0 Max	1.5
Microbiological Parameters					
15	E.coli /100ml	IS 15185 - 2016 (RA 2021)	Absent	Absent	Absent
16	Coliforms/100ml	IS 15185 - 2016 (RA 2021)	Absent	Absent	Absent

INFERENCE: As per IS Standards 10500 - 2012, The above tested results are within the limits.

H. Sultta
ANALYZED BY

Patta.S
MICROBIOLOGIST



Sowjanya Q. K.
AUTHORISED SIGNATOR
K. SOWJANYA
Sr. Chemist

End of the Report

SHILPA
Sr. Microbiologist

- Note:
- The results refer only to the tested samples and applicable Parameters
 - This report not to be reproduced wholly or in part & Cannot be used as an evidence in the Court of Law
 - Samples will be stored for a period of 15 Days on receipt ,unless otherwise specified.
Perishable samples shall be destroyed immediately after analysis.
 - Nexus Test Labs doesnot hold any responsibility for variation in test results for samples kept on hold for want of clarification

RECEIVED
AKL/19
12/03/25

NEXUS TEST LABS PVT. LTD.,

Sy.No-114, Site No: 115,116 1st & 2nd Floor, Rajapalya, Hoodi Gardens, Mahadevapura Post, Whitefield Road, Bangalore - 560 048
Tel : +91 8050448777, Email : info@nexusstestlabs.com, Web : nexusstestlabs.com



TC-14309



National Accreditation Board for
Testing and Calibration Laboratories

NABL

CERTIFICATE OF ACCREDITATION

NEXUS TEST LABS PVT LTD

has been assessed and accredited in accordance with the standard

ISO/IEC 17025:2017

**"General Requirements for the Competence of Testing &
Calibration Laboratories"**

for its facilities at

SY NO-114, SITE NO 115,116, 1ST & 2ND FLOOR, RAJAPALYA, HOODI GARDENS, MAHADEVAPURA
POST, WHITE FIELD, BENGALURU, KARNATAKA, INDIA

in the field of

TESTING

Certificate Number: TC-14309

Issue Date: 17/08/2024

Valid Until:

16/08/2026

This certificate remains valid for the Scope of Accreditation as specified in the annexure subject to continued satisfactory compliance to the above standard & the relevant requirements of NABL.
(To see the scope of accreditation of this laboratory, you may also visit NABL website www.nabl-india.org)

Name of Legal Entity: NEXUS TEST LABS PRIVATE LIMITED

Signed for and on behalf of NABL



N. Venkateswaran
Chief Executive Officer